



**PRINCE WILLIAM COUNTY**  
**Department of Development Services – Building Development Division**

**BUILDING INSPECTION CERTIFICATION**

Version 2012-01-15

Architect/Engineer Data	Project/Site Data
Name: _____	Building Permit #: _____ Owner/Builder: _____
Address: _____	Site Address: _____
Phone #: _____	Project/Subdivision: _____ Section: ____ Lot #: ____
	Soil Category: <input type="checkbox"/> I <input type="checkbox"/> II <input type="checkbox"/> III

✓	ITEM	DATE	INSPECTOR
<b>FOOTING &amp; FOUNDATION</b>			
	Controlled Fill placed under the Site Permit*		
	Controlled Fill placed under this Building Permit*		
	Footings: On Grade Design Soil Bearing = 1500 psf		
	Footings: On Grade Design Tested Soil Bearing > 1500 psf*		
	Footings: On Controlled Fill*		
	Pile foundation		
	Pier foundation		
	Deck/porch		
	Concrete wall/steel rebar		
	Backfill (below grade seal)		
	• Drain Mechanical		
	• Drain-Gravity/Daylight		
	• Wall Soil Lateral Pressure Design < 60 psf*		
	• Wall Soil Lateral Pressure Design = 60 psf with MH or Inorganic CL*		
	• Wall Soil Lateral Pressure Design = 60 psf with SC, ML-CL, or better		
	• Dampproofing		
	• Waterproofing		
<b>MASONRY</b>			
	Masonry Construction		
	Masonry Hearth		

✓	ITEM	DATE	INSPECTOR
<b>SLAB on grade (OG), controlled fill (CF)*, structural(S)</b>			
	Grade level OG□, CF□, S□		
	Basement OG□, CF□, S□		
	Garage level OG□, CF□, S□		
	Stoop/porch OG□, CF□, S□		
	Areaway OG□, CF□, S□		
	Elevated Level		
<b>STEEL</b>			
	Structural Steel		
	Cold Rolled Steel		
<b>FIRE PROTECTION</b>			
	Through Penetration Firestop System**		
	Sprayed cementitious**		
	Mineral Fiber**		
<b>CONCRETE ENCASED GROUNDING ELECTRODE</b>			
	Minimum 20' of 1/2" rebar		
	Minimum of 20' of #4 copper conductor		
<b>OTHER INSPECTIONS</b>			
	Approved by Building Official		
	Foundation Structural Repair		
	Exterior Insulation Finish System (EIFS) **		
	Structural repair(s)		

\*Professional Engineer's certification with soil data and test results attached.

\*\*Must attach ICC, NES or BOCA Research Report and/or manufacturer's instructions for installation and

At the time of this inspection, all items inspected were in accordance with the County approved building plans and the Virginia Uniform Statewide Building Code; a copy of the required building permit was posted on the construction site. Additionally, the erosion control devices were properly installed and maintained; or the Department of Public Works was notified within one business day of an erosion control deficiency in accordance with [Policy 1.16 Third Party Inspection Certification Program](#).

Architect/Engineer Seal           Signature: _____ Date: _____	Prince William County/Comments:           Date: _____
---	--