

4/19.

Will Cumming:

Q. Tree driveway need to be 50' wide?

WC

" min 30' max 50' $\pm$ adeq. width
to handle traffic coming in & going
out of church. Highway dept. did not
req. the 50' width.

~~If~~

Firelane reqt.? Highway Dept. does not
req. the fire lane.

call county number & ask for
Fire Marshall's

Pulls the site plan -

No reqt. of 50' entrance -

but only that need 25' radiuses on
entrance shown is 30 feet wide.

Site distance on Sudley Manor Drive.

